

FEATURES

- · Sanitary design
- · Solid bar-stock drilled

Bar-stock





APPLICATION


- Biochemical & pharmacuetical
- Food & beverages
- Sterile process industries

STANDARD SPECIFICATIONS							
Shank form		Straight					
Material	:	AISI 316 SS					
Instrument connection	:	½" NPT (F) / ½" BSP (F)					
Bore diameter	:	6.6 mm					
Lag extension	:	50 mm					
Root diameter	:	21.0 mm					
Tip diameter	:	21.0 mm					
Immersion length	:	150 mm					
Step / Taper Length	:	150 mm					
Tip thickness	:	5 mm					
Process connection	:	1½" Tri-clover connection					
Head type	:	Round with spanner slot					
Head size	:	27 mm					

DIMENSIONAL DRAWING







W202

SANITARY THERMOWELL



ORDERING CODES							
1. SHANK FORM			13. STEP STYLE				
S E T	Straight Stepped Tapered	\$	S T	Straight Taper	— s		
2. MATERIAL			9. STEP / TAPER LENGTH ("S")		— 150		
MF	AISI 316 SS	MF	XXX	Mention in 'mm'	100		
MG	AISI 316L SS		10 TIP T	THICKNESS ("t")			
3. INSTRUMENT CONNECTION			M 5 mm		M		
02N 04N	1/4" NPT (F) 1/2" NPT (F)	02N	N O	6.35 mm (½") 10 mm			
05N 02B	3/4" NPT (F) 1/4" BSP (F)		11. PROCESS CONNECTION		T15		
04B 05B 04M	½" BSP (F) ¾" BSP (F) M20 x 1.5 mm (F)		T01 T02 T15 T25	1" Tri-clover connection 2" Tri-clover connection 1½" Tri-clover connection 2½" Tri-clover connection			
4. BORE DIAMETER ("d")		_	12. HEAD TYPE				
N A C	6.35 mm (½") 6.6 mm 9.0 mm 9.6 mm	- А	H L 13. HEAI	Hex Round with spanner slot	— L		
0	10 mm		XX	Mention in 'mm'	27		
5. LAG EXTENSION ("T")							
XXX	35 mm up to 250 mm	50	14. OTH	ER OPTIONS	— XM		
	DIAMETER ("Q")	21	XI XK XL	Plug & chain in SS Electro polishing Marking by laser			
XX.X	Mention in 'mm' AMETER ("D")		XM TD	Marking by engraving Dye penetration test			
XX.X	Mention in 'mm'	21	TG TH	IGC test Hydro test certificate			
	RSION LENGTH ("U")	150	TM TN TP	Material test certificate 2.2 Tested to NACE standards Performance test certificate			
XXXX	50 mm up to 1000 mm		TW	WFC as per PTC 19.3TW:2010			

Ordering Example: W202-S-MF-02N-A-50-21-21-150-S-150-M-T15-L-27-XM

NOTES

1. Other diameters, connections are available, please contact factory for details.

2. Please refer "Technical Guidance Sheet" for the proper selection of connections according to Head size and Outer diameter of the well.

